

81 Apollo Drive, Rosedale, Auckland 0632, New Zealand Tel: +64 9 634 2893

### Class 1

# Pressure & Temperature Relief Valves

# **Building Product Information Requirements (BPIR)**

**Product Line:** RMC pressure & temperature relief valves

#### **Product Identifier(s):**

2154-0850kPa, HT5003, HT5005, HT5007, HT5009, HT501, HT5010, HT5011, HT5012, HT5013, HT5016, HT5017, HT5022, HT5023, HT5024, HT5025, HT5029, HT503, HT505, HT505-1, HT505i, HT507, HT507-1, HT511, HT511-1, HT547, HT548, HT551, HT552, HT553, HT557, HT558, HT574, HT576, HT577, HT579, HT592, HT597, HT598, HT599, HT7000, HT7003, HT701, HT703, HT705, HT705l, HT706, HT707, HT711, HTE501, HTE502, HTE504-1, HTE504-1, HTE506, HTE507, HTE508, HTE509, HTE511, HTE513, HTE521, HTE522, HTE523, HTE526, HTE527, HTE701, HTE703, HTE705, HTE709, HTE710, HTE715, HTE717, HTT515, HTT516, HTT517, HTT518, HTT518-1, HTT519, HTT527, HTT530, HXT503, RYEHT505, RYEHT507, RYEHT511, RYEHTE504, RYEHTE506

### **Product Description:**

DN15-DN20 pressure & temperature relief valves for use with unvented storage water heaters.

### Relevant building code clauses:

B2 Durability —	B2.3.1 (a)
F2 Hazardous building materials —	F2.3.1
G10 Piped services —	G10.3.1
G12 Water Supplies —	G12.3.2, G12.3.7
H1 Energy efficiency —	H1.3.3

## **Contributions to compliance:**

All items listed under Product Identifier(s) are approved to AS1357.1-2019. WaterMark licence number 000938.



81 Apollo Drive, Rosedale, Auckland 0632, New Zealand Tel: +64 9 634 2893

### Scope of use:

The RMC Pressure and Temperature (P&T) Relief Valve is a safety/protection control for use with unvented storage water heaters. It ensures that the pressure does not exceed the maximum pressure for the water heater and the temperature of the water does not exceed 99°C, in the event the normal temperature controls fail.

#### Conditions of use:

RMC Reliance Valves P&T relief valves must be installed by a suitably qualified person according to the rules of AS/NZS 3500.4.

# **Supporting Documentation:**

Title (Type)	Version / Date	URL
RMC Reliance Valves	N/A	Click Here
Pressure & Temperature		
Relief Valve		



81 Apollo Drive, Rosedale, Auckland 0632, New Zealand Tel: +64 9 634 2893

#### **Contact Details:**

Manufacture Location:	Overseas
Legal and trading name of	Reliance Worldwide Corporation
Manufacturer:	(AUST.) Pty. Ltd.
Manufacturer address for	27 – 28 Chapman Place, Eagle
service:	Farm, QLD 4009Australia
Manufacturer website:	www.rmc.com.au
Manufacturer NZBN:	
Manufacturer email:	sales.au@rwc.com
Manufacturer phone number:	+61 07 3018 3400

Importer Location:	New Zealand
Legal and trading name of	Reliance Worldwide Corporation
Importer:	(NZ). Pty. Ltd.
Importer address for service:	81 Apollo Drive, Rosedale,
	Auckland 0632
Importer website:	www.relianceworldwide.co.nz
Importer NZBN:	9429000011358
Importer email:	sales.nz@rwc.com
Importer phone number:	0800 800 523

## **Warnings and Bans:**

Is the building product/building product line subject to warning or ban under section 26 of the Building Act 2004?

No

Version: 1.0

**Date:** 2/11/2023

Reliance Worldwide Corporation (New Zealand) Pty. Ltd. reserves the right to change any product specification or information contained in this publication at any time and without notice. All diagrams are illustrative only. Please consult OEM instructions and AS/NZS 3500 for all installations.