

INSTALLATION INSTRUCTIONS

Combination Non-Return Isolating Valves

INSTALLATION INSTRUCTIONS

- 1. Flush water lines before connection.
- 2. Must be fitted by a licenced plumber in accordance with AS/NZS 3500.1.
- 3. Install valve with direction of flow as indicated by arrow on valve body.
- 4. Suitable for horizontal or vertical installation.
- 5. Ensure knob is easily accessible.

TECHNICAL SPECIFICATIONS

Maximum Pressure: 1400kPa Maximum Temperature: 40°C

WARRANTY

Reliance Worldwide Corporation reserves the right to modify designs and specifications and to withdraw and introduce products at any time without notice.

Installation is subject to the requirements of the applicable regulatory authority, the National Construction Code Volume Three – Plumbing Code of Australia, associated reference standards as applicable at the time and AS/NZS 3500. This product is compliant to the Lead Free requirements of the National Construction Code Volume Three. For further Scope of Use, please visit www.rmc.com.au/resources.

Reliance Worldwide Corporation (Aust.) Pty. Ltd. (RWC) will either replace or repair any defective goods where the defect arose as a result of manufacture for two (2) years (see website for more details). You may contact RWC at the phone number, address or e-mail shown and will be required to return the goods for evaluation. Should the defect be found to be one of our manufacture we will send you a replacement product to your stated address at our expense. Our goods come with guarantees that cannot be excluded under Australian Consumer Law. You are entitled to a replacement or refund for a major failure and for compensation for any other reasonably foreseeable loss or damage. You are also entitled to have the goods repaired or replaced if the goods fail to be of acceptable quality and failure does not amount to a major failure.

® = Registered Trade Mark of Reliance Worldwide Corporation

© 2024 All rights reserved

CUSTOMER SERVICE

AU 1800 810 803 | NZ 0800 800 523 | sales.au@rwc.com | www.rmc.com.au